



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

September 22, 2009

ZEROFLUSH INC.
JOE ROMERO/ DOROTHY BARNWELL
3008 LIONS CT
KISSIMMEE FL 34744

ZEROFLUSH, INC
GEORG KUENG
3008 LIONS CT
KISSIMMEE FL 34744

Re: Description: URINAL
Manufacturer: ZEROFLUSH, INC
Product Name: ZERO FLUSH
Model Number(s): ZF-101, ZF-201, ZF-401, ZF-501
Product File No: 20090326

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.20 (5) (n) 1.a. and 82.32 (2) & (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This waterless urinal is not recommended to be installed on copper drain lines.
- This urinal shall be installed per manufactures instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov